

DATE: August 13, 2008

JOB NAME: PROLOGIS
HVAC INSPECTION REPORT AT 2501 109th STREET

UNIT NUMBER	MAKE MODEL	UNIT CONDITION	PRICE TO REPAIR
RTU #1 AGE 23 YRS 5 TON	CARRIER 48LDT006510DA 1285G18939	O.K. BUT IN POOR CONDITION DUE TO AGE	\$0.00
RTU #2 AGE 23 YRS 5 TON	CARRIER 48LDT006510DA 1285G18937	*REPLACE CONDENSER FAN MOTOR *REPLACE 2 POLE CONTACTOR	\$680.00
RTU #3 AGE 11 YRS 7.5 TON	CARRIER 48TJD008611 2797G30773	*REPLACE AIR FILTERS(6=20X20X1) *REPLACE (A-48) *REPLACE 2 POLE CONTACTOR	\$180.00
UNIT HEATER #1	STERLING	O.K.	\$0.00
UNIT HEATER #2	STERLING	O.K.	\$0.00
UNIT HEATER #3	STERLING	O.K.	\$0.00
EXHAUST FAN WOMENS ROOM	DAYTON	NO POWER	\$0.00
EXHAUST FAN MENS ROOM	DAYTON	NO POWER	\$0.00

EXCLUSIONS

SALES TAX

* REPAIRS WILL CARRY A 90 DAY WARRANTY UNLESS OTHERWISE STATED.

* PRICING WILL BE GOOD FOR 30 DAYS

Sincerely

NAME _____
SIGNATURE _____
DATE _____