



Addendum #1

page 1

To: Bidders of Record

Project: Pitman at 2601 Resource Drive su. 300, Plano

Date of Issue of Addendum: 05.08.2009

Issued by: Space Planning Specialists (contact: Becky Whitworth 972/414-9391)

Questions on this project shall be directed to: Mark Stahl, Space Planning Specialists 972/414-9391

This addendum forms part of the Construction drawings issued for pricing dated May 8, 2000 and is to be acknowledged on your Bid Form.

Attachments: None

- 
1. Add 6" R-19 insulation to deck in new demising partition.
  2. There is no new dock high ramp. The ramp is currently existing.
  3. The double doors shown in conference 106 are to be a new door and frame. The doors shall be a pair of 3'x7' solid core with a lock set and edge bolt flush mounts.
  4. Price as alternate a new break room cabinet and sink in lieu of relocating the existing cabinet and sink.
  5. Provide 18 telephone / data rough-in's in the office area.
  6. In the warehouse area: provide 8 duplex outlets in the warehouse. Location to be determined.
  7. In the warehouse area: provide (2) 208v. 30 amp. 3 phase outlets for fork life chargers. Location to be close to overhead doors.

End of Addendum #1