


**DOCUMENT 00701
ADDENDUM NUMBER 02**



DATE: January 12, 2009
PROJECT: Renovations to Cashier area
South Water Utilities Department
1100 S. W. Green Oaks Blvd.
PROJECT NUMBER: WUD-0702
OWNER: City of Arlington
CONSULTANT: Easum Engineering
2860 State Hwy. 66, suite 100
Rockwall, Texas 75087
Ph: (972) 234-9911 Fax (972) 234-9922
TO: Prospective Bidders

This Addendum forms a part of the Contract Documents and modifies the Bidding Documents dated December 30, 2008, January 09, 2009 with amendments and additions noted below. Acknowledge receipt of this Addendum in the space provided in the Bid Form. Failure to do so may disqualify the Bidder.
This Addendum consists of one (1) page.

CHANGES TO DRAWINGS:

1. Sheet A1.20: Delete demolition Key Note No. 15. Contractor shall provide conduit and wire concealed in header for electrical and data, in lieu of saw cutting the existing concrete slab.

End of Addendum